

TOTAL ORGANIC CARBON, ROUTINE MAJOR

The **City Of Eagle Pass Water Works System, TX1620001**, has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30TAC), Section 290, Subchapter F. Public water systems that use a series of treatment processes that includes coagulation, flocculation, sedimentation or clarification, and filtration as part of the overall treatment protocol must monitor Total Organic Carbon and report the results of that monitoring to the TCEQ on a monthly basis.

We failed to monitor and/or report the following: Total Organic Carbon.

This/These violations(s) occurred in the monitoring periods(s): June 2019

Results of monitoring are an indicator of whether drinking water is protected from potential adverse health effects associated with disinfectants and disinfection by-products. We did not complete all monitoring and/or reporting for disinfectant by-products precursors, and therefore TCEQ cannot be sure of the Total Organic Carbon levels in your drinking water during that time.

We are taking the following actions to address this issue:

The City of Eagle Pass Water Works System has always been, and continues to be in full compliance with Total Organic Carbon monitoring and/or reporting. However, in June 2019, a TOC sample was collected but not sent out. Since then, our sample handling process has been corrected and improved. Our continued commitment to the highest quality standards continues to make us a superior water system.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions regarding this matter, please contact Jorge Flores, Asst. General Manager at 830-773-2351.

Posted/ Delivered on: April/3/2020